







Technical Data	LF24-3(-S) US
Power supply	24 VAC ± 20% 50/60 Hz
	24 VDC ± 10%
Power consumption	
runnin	g 2.5 W
holdin	g 1 W
Transformer sizing	5 VA (class 2 power source)
Electrical connection	
LF24-3 US	3 ft, plenum rated cable
	1/2" conduit connector
LF24-3-S US	3 ft, 18 GA appliance cables (2)
	1/2" conduit connectors
Overload protection	electronic throughout 0 to 95° rotation
Input impedance	1000 Ω (0.6w) control inputs
Angle of rotation	max. 95°, adjust. with mechanical stop
Torque	35 in-lb [4 Nm]
Direction of rotation	
sprin	g reversible with cw/ccw mounting
	r reversible with built-in switch
Position indication	visual indicator, 0° to 95°
	(0° is spring return position)
	r 150 sec constant, independent of load
sprin	g < 25 sec @-4°F to 122°F [-20°C to 50°C]
	< 60 sec @-22°F [-30°C]
Humidity	5 to 95% RH non-condensing
Ambient temperature	-22°F to 122°F [-30°C to 50°C]
Storage temperature	-40°F to 176°F [-40°C to 80°C]
Housing	NEMA type 2 /IP54
Housing material	zinc coated metal
Agency listings	cULus acc. to UL 873 and
	CAN/CSA C22.2 No. 24-93
	g < 30 db (A)
Servicing	maintenance free
Quality standard	ISO 9001
Weight LF24-3	3.1 lbs (1.40 kg)
LF24-3-S	3.6 lbs (1.45 kg)
LF24-3-S US	
Auxiliary switch	1 x SPDT 3A (0.5A) @ 250 VAC, UL Approved
Auxiliary Switch	adjustable 0° to 95° (double insulated)

Torque min. 35 in-lb, for control of air dampers

Application

For modulation or On/Off control of dampers in HVAC systems. Actuator sizing should be done in accordance with the damper manufacturer's specifications.

The actuator is mounted directly to a damper shaft from 3/8" up to 1/2" in diameter by means of its universal clamp, 1/2" shaft centered at delivery. For shafts up to 3/4" use K6-1 accessory. A crank arm and several mounting brackets are available for applications where the actuator cannot be direct coupled to the damper shaft.

Control is floating point from a triac or relay, or On/Off from an auxiliary contact from a fan motor contactor, controller, or manual switch.

Operation


The LF series actuators provide true spring return operation for reliable fail-safe application and positive close-off on air tight dampers. The spring return system provides consistent torque to the damper with, and without, power applied to the actuator.

The LF series provides 95° of rotation and is provided with a graduated position indicator showing 0 to 95°.

The LF24-3 (-S) US uses a brushless DC motor which is controlled by an Application Specific Integrated Circuit (ASIC) and a microprocessor. The microprocessor provides the intelligence to the ASIC to provide a constant rotation rate. The ASIC monitors and controls the brushless DC motor's rotation and provides a digital rotation sensing function to prevent damage to the actuator in a stall condition. The actuator may be stalled anywhere in its normal rotation without the need of mechanical end switches.

Power consumption is reduced in holding mode.

The LF24-3-S US version is provided with one built-in auxiliary switch. This SPDT switch is provided for safety interfacing or signaling, for example, for fan start-up. The switching function is adjustable between 0° and 95°. The auxiliary switch in the LF24-3-S US is double insulated so an electrical ground is not necessary.



M40024 - 05/10 - Subject to change.

Belimo Aircontrols (USA), Inc.



Accessories	
AV 10-18	Shaft extension (K6-1 is required)
IND-LF	Damper position indicator
K6-1	Universal clamp for up to 3/4" diameter shafts
KH-LF	Crank arm for up to 1/2" round shaft
Tool-06	8mm and 10 mm wrench
ZG-LF2	Crank arm adaptor kit for LF
ZG-112	Mounting bracket for Honeywell Mod IV, M6415 type actuators, and new installations
ZG-LF112	Crank arm adaptor kit for Honeywell Mod IV,
20-61112	M6415 type actuators, and new installations
ZS-100	Weather shield (metal)
ZS-150	Weather shield (polycarbonate)
ZS-260	Explosion-proof housing
NOTE: When using LE24-3 (-S) US actuators, only use accessories listed on this page	

NOTE: When using LF24-3 (-S) US actuators, only use accessories listed on this page. For actuator wiring information and diagrams, refer to Belimo Wiring Guide.

Typical Specification

Floating point, On/Off spring return damper actuators shall be direct coupled type which require no crank arm and linkage and be capable of direct mounting to a shaft up to a 3/4" diameter and center a 1/2" shaft. The actuators must be designed so that they may be used for either clockwise or counterclockwise fail-safe operation. Actuators shall have an external direction of rotation switch to reverse control logic. Actuators shall use a brushless DC motor and be protected from overload at all angles of rotation. If required, one SPDT auxiliary switch shall be provided having the capability of being adjustable. Actuators with auxiliary switch must be constructed to meet agency listings. Run time shall be constant and independent of torque. Actuators shall be cllLus listed, have a 5 year warranty, and be manufactured under ISO 9001 International Quality Control Standards. Actuators shall be as manufactured by Belimo.

Wiring Diagrams

INSTALLATION NOTES

Provide overload protection and disconnect as required.

CAUTION Equipment Damage! Actuators may be connected in parallel.

Power consumption and input impedance must be observed.

3 Actuators may also be powered by 24 VDC.

The Common connection from the actuator must be connected to the Hot

\ The actuator Hot must be connected to the control board Common.

For end position indication, interlock control, fan startup, etc., LF24-3-S US LF120-S US and LF230-S US incorporate one built-in auxiliary switch: 1 x SPDT, 3A (0.5A) @250 VAC, UL Approved, adjustable 0° to 95°.

Actuators with plenum rated cable do not have numbers on wires; use color coded instead. Actuators with appliance rated cable use numbers. **†** LF24-3 US, Green wire #4, LF24-3-S US, White wire #5

APPLICATION NOTES

Meets cULus requirements without the need of an electrical ground connection.

WARNING Live Electrical Components!

During installation, testing, servicing and troubleshooting of this product, it may be necessary to work with live electrical components. Have a qualified licensed electrician or other individual who has been properly trained in handling live electrical components perform these tasks. Failure to follow all electrical safety precautions when exposed to live electrical components could result in death or serious injury.

